

EU-DECLARATION OF CONFORMITY

We, **Hadro Techniek B.V.**
Westbaan 270
NL-2841 MC Moordrecht
Tel +31 182 527190
E-mail info@hadro.nl
Website www.hadro.nl

herewith declare, that the

Level switch, type HLS-25 i and HLS-25 d

Complies with the

EU Directive

2014/34/EU (ATEX)

The instruments have been tested in compliance with the norms:

EN 60079-0 : 2012

EN 60079-11 : 2012

The products will be marked with:

HLS-25 i (Exi):

Exia IIC T6Ga
Exia IIIC T85°C IP66/67 Da
Tamb: -20° to + 85°C

HLS-25 d (Exd):

Exd IIC T6 Gb
Extb IIIC T85Db
Tamb: -20° to +70°C

Certificate nr: Baseefa14ATEX0013X

Certificate nr. Baseefa14ATEX0256X

The certification was carried out by:

NoBo EU Type Examination:

SGS-Baseefa Ltd (1180)
Rockhead Business Park
Staden Lane
Buxton
Derbyshire
SK17 9RZ
U.K.

NoBo for Production:

Sira Test & Certification Ltd (0518)
Unit 6 Harwarden Industrial Park
Harwarden
Deeside
CH5 3US
U.K.

The Netherlands,
Moordrecht
10th July 2017



Hadro Techniek B.V.

Westbaan 270
NL -2841 MC Moordrecht
Tel: +31 182 527190
info@hadro.nl www.hadro.nl

J.M. Drost
director